Our Ref:

HL/M1303017

Test Report: MA4856/V

21st October 2013



CRC Industries UK Ltd. Wylds Road, Castlefield Industrial Estate, Bridgewater, Somerset, TA6 4DD

WATER REGULATIONS ADVISORY SCHEME (WRAS) MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

5160 **LUBRICANTS**

Ambersil Silicone Anti-Stick and Ambersil Silicone Lubricant. Clear liquid lubricants. Apply as per manufacturer's instructions. For use with water up to 85°C.

APPROVAL NUMBER: 1310510

APPROVAL HOLDER:

CRC INDUSTRIES UK LTD.

The Scheme reserves the right to review approval. This approval is valid between October 2013 and October 2018.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

Jason Furnival

Approvals & Enquiries Manager

Water Regulations Advisory Scheme